

# Residential Houses converting to Assisted Living Facilities (ALF) / Adult Family Care Home (AFCH)

## Procedures for all facilities

A Change of Occupancy permit will be required per the Florida Fire Prevention Code, 5<sup>th</sup> Edition, NFPA 1- 1.7.11.5 and the Florida Building Code, Existing Building, 5<sup>th</sup> Edition (2014). This application is to be submitted at the Building Division.

A copy of a site plan and a floor plan, showing the intended layout of all rooms, are required for submittal. On the floor plan, identify bed locations, exit locations and fire extinguisher locations. The bathroom(s) are required to comply with the Florida Building Code Building, Chapter 4, Section 464.4.5. Application Submittal to include copy of required details to show compliance.

Please include with the floor plan lay-out; the number of residents and their evacuation capabilities (impractical, prompt or slow). Please provide copies of any State paperwork required for licensing.

NFPA 101- 3.3.76.1 *Impractical Evacuation Capability*. The inability of a group to reliably move to a point of safety in a timely manner (more than 13 minutes).  
3.3.76.2 *Prompt Evacuation Capability*. The ability of a group to move reliably to a point of safety in a timely manner that is equivalent to the capacity of a household in the general population (3 minutes or less).  
3.3.76.3 *Slow Evacuation Capability*. The ability of a group to move reliably to a point of safety in a timely manner, but not as rapidly as members of a household in the general population (over 3 minutes but not in excess of 13 minutes).

Per the Florida Building Code, Section 903.2.8, *Fire Sprinklers are required in all ALFs and AFCHs*, regardless of the number of residents.

A Fire Sprinkler permit shall be applied for by a State of Florida licensed Fire Sprinkler contractor.

A Fire Alarm permit may be applied for by a State of Florida licensed Fire Alarm contractor.